



ACOUSTICAL PERFORMANCE RATING  
CERTIFICATION PROGRAM  
ATI-AA676

## Security Screen and Storm Shutter Certification Program

### Certified Product List for:

**Company:** **Crimsafe North America LLC**

**Corporate Address:** 3020 Reynolds Road, Units 1 – 3  
Lakeland, Florida 33803

**Plant Location:** 3020 Reynolds Road, Units 1 – 3  
Lakeland, Florida 33803

**Website:** [www.crimsafe.com](http://www.crimsafe.com)

**Phone:** 863-510-0811

**Facsimile:** 863-665-0485

**Participant Since:** 01/19/11

Note: The manufacturer posted on this Security Screen and Storm Shutter Certification Listing is a participant in good-standing in the Architectural Testing Security Screen and Storm Shutter Certification Program. The products listed have been verified by Architectural Testing during unannounced manufacturing site audits. This Certification Listing is not an endorsement of the manufacturer or products listed herein.



ACOUSTICAL PERFORMANCE RATING  
CERTIFICATION PROGRAM  
ATI-AA676

## Security Screen and Storm Shutter Certification Program

### Certified Product List for:

**Company: Crimsafe North America LLC**

**Product : Series/Model: Patio Enclosure Security Screen**

**Type:** Aluminum Patio Enclosure with Stainless Steel Mesh

**Size Tested:** 15' 7" wide x 11' 11-11/16" high

**Glazing/Infill:** 304 Stainless Steel Mesh Screen

**Test Methods/Test Results:**

ASTM E1886 / E1996: Wind Zone 4 Missile Level D

ASTM E330: Design Pressure: Positive 50.0 Negative 50.0

Structural Test Pressure: Positive 75 Negative 75

Note: The manufacturer posted on this Security Screen and Storm Shutter Certification Listing is a participant in good-standing in the Architectural Testing Security Screen and Storm Shutter Certification Program. The products listed have been verified by Architectural Testing during unannounced manufacturing site audits. This Certification Listing is not an endorsement of the manufacturer or products listed herein.



ACOUSTICAL PERFORMANCE RATING  
CERTIFICATION PROGRAM  
ATI-AA676

## Security Screen and Storm Shutter Certification Program

### Certified Product List for:

**Company: Crimsafe North America LLC**

**Product : Series/Model: Safe-S-Cape**

**Type:** Aluminum Hinged Impact Window Screen

**Size Tested:** 55" wide x 85" high

**Glazing/Infill:** 304 Stainless Steel Mesh Screen

**Test Methods/Test Results:**

ASTM E1886 / E1996: Wind Zone 4 Missile Level D

ASTM E330: Design Pressure: Positive 75.0 Negative 75.0

Structural Test Pressure: Positive 112.5 Negative 112.5

SMA 6001 Section 3.3.8 Heavy

SMA 6001 Section 4.3.3.2 Heavy

Note: The manufacturer posted on this Security Screen and Storm Shutter Certification Listing is a participant in good-standing in the Architectural Testing Security Screen and Storm Shutter Certification Program. The products listed have been verified by Architectural Testing during unannounced manufacturing site audits. This Certification Listing is not an endorsement of the manufacturer or products listed herein.



ACOUSTICAL PERFORMANCE RATING  
CERTIFICATION PROGRAM  
ATI-AA676

## Security Screen and Storm Shutter Certification Program

### Certified Product List for:

**Company: Crimsafe North America LLC**

**Product : Series/Model: Hinged-Screen Hurricane Door**

**Type:** Aluminum Side-Hinged Screen Door with Stainless Steel Mesh

**Size Tested:** 42" wide x 81" high and 42" wide x 96" high

**Glazing/Infill:** 304 Stainless Steel Mesh

**Test Methods/Test Results:**

ASTM E1886 / E1996: Wind Zone 4 Missile Level D

ASTM E330: Design Pressure: Positive 50.0 Negative 50.0

Structural Test Pressure: Positive 75.0 Negative 75.0

SMA 6001 Section 3.3.8 Heavy

SMA 6001 Section 4.3.3.2 Heavy

Note: The manufacturer posted on this Security Screen and Storm Shutter Certification Listing is a participant in good-standing in the Architectural Testing Security Screen and Storm Shutter Certification Program. The products listed have been verified by Architectural Testing during unannounced manufacturing site audits. This Certification Listing is not an endorsement of the manufacturer or products listed herein.



ACOUSTICAL PERFORMANCE RATING  
CERTIFICATION PROGRAM  
ATI-AA676

## Security Screen and Storm Shutter Certification Program

### Certified Product List for:

**Company: Crimsafe North America LLC**

**Product : Series/Model: Fixed Build – Out Security Screen**

**Type:** Aluminum Frame, Build-Out Fixed Window Impact Screen

**Size Tested:** 53-1/8” wide x 84-7/8” high

**Glazing/Infill:** 304 Stainless Steel Mesh

**Test Methods/Test Results:**

ASTM E1886 / E1996: Wind Zone 4 Missile Level D

ASTM E330: Design Pressure: Positive 75.0 Negative 75.0

Structural Test Pressure: Positive 112.5 Negative 112.5

SMA 6001 Section 3.3.8 Medium

SMA 6001 Section 4.3.3.2 Medium

Note: The manufacturer posted on this Security Screen and Storm Shutter Certification Listing is a participant in good-standing in the Architectural Testing Security Screen and Storm Shutter Certification Program. The products listed have been verified by Architectural Testing during unannounced manufacturing site audits. This Certification Listing is not an endorsement of the manufacturer or products listed herein.